



## Installation Instructions for Labeled Frames and Doors for Positive Pressure Applications.

### Frames

Hollow metal fire door frames are labeled for compliance with NFPA 252 and UL 10C positive pressure requirements. These frames also meet the requirements of UL 10B and UL 1784.

A door labeled for NFPA 252 or UL 10C positive pressure compliance must be installed in each of these door frames. See the appropriate door installation instructions.

Intumescent seals are not required for hollow metal frames with hollow metal doors to comply with UL 10C. If a wood door is being installed in a hollow metal frame, the door must be installed in accordance with the wood door manufacturer's labeling procedure and installation instructions. **Intumescent seals may be required for wood doors.**

Fire door frames (and approved doors) must be installed with the manufacturer's instructions or ANSI A250.11 "[Recommended Erection Instructions for Steel Frames](#)" or [HMMA 840 "Installation and Storage of Metal Doors and Frames"](#) and in accordance with NFPA 80.

If frames are placed on uneven floors, adjustable floor anchors may be used to compensate. In lieu of adjustable floor anchors, fixed base anchors may be shimmed up to 3/8" using washers or metal shims. Any resulting gap must be filled with mortar or fire resistant caulking.

Listed hardware is to be used in accordance with NFPA 80.

When loose jamb anchors are used for wall attachment, one shall be provided for every 30 inches of jamb opening height, or fraction thereof.

### SMOKE AND DRAFT CONTROL:

Smoke and draft control openings require the use of "Category H" gasketing that is labeled for compliance to UL 1784. See the gasketing manufacturer's installation instructions.

Louvers are not permitted in smoke and draft control openings and the installation of a louver in a fire door renders void any "S" that may be indicated on the door or frame label.

## **Doors**

Hollow metal fire doors are labeled for compliance with NFPA 252 and UL 10C positive pressure requirements. These doors also meet the requirements of UL 10B.

Doors must be installed in frames labeled for NFPA 252 or UL 10C positive pressure compliance, or at the discretion of the Authority Having Jurisdiction, in a frame labeled for compliance with UL 10B. See the appropriate frame installation instructions.

Intumescent seals are not required for hollow metal doors with hollow metal frames to comply with UL 1784.

Fire doors (and approved door frames) must be installed with the manufacturer's instructions or HMMA 840 "Installation and Storage of Metal Doors and Frames" and in accordance with NFPA 80.

Listed hardware is to be used in accordance with NFPA 80. Door clearances must also meet the requirements of NFPA 80.

Lite kits must be approved for positive pressure requirements and must be installed in accordance with the lite kit manufacturer's installation instructions. Only listed louvers are permitted in positive pressure fire rated doors. Doors with un-channeled light or louver cut-outs are intended for use with Anemostat kits utilizing HM-Clips or with those Air Louver kits which are approved for installation without channeling.

### **SMOKE AND DRAFT CONTROL:**

Smoke and draft control openings require the use of "Category H" gasketing and bottom sweeps that are labeled for compliance to UL 1784. See the gasketing manufacturer's installation instructions.

Louvers are not permitted in smoke and draft control openings and the installation of a louver in a fire door renders void any "S" that may be indicated on the door or frame label.